

Slip Check to AS 4586:2013 Resysta Decking by Harpro

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

16 March 2016

Test Report No. R10392

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.


Requested by: Homebuild Global
Client Address: 1a, 62-66 Newton Road
Wetherill Park NSW 2164
Product Manufacturer: Resysta Asia Pty Ltd
Product Description: Resysta Decking by Harpro

Test conducted according to: AS 4586:2013 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148
Conducted by: Dale Rowell

Date: 15 March 2016 Temperature: 27°C
Sample: Unfixed Cleaning: None
Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed
Slope of specimen: Tested on a flat level surface by wet lapping film
Direction of Test: NA

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	56	56	56	56	57

Reported SRV of Sample:	56
Class:	P5



Martin Daniel
Materials Scientist